

## ANALYSIS OF IMPROVING THE OPERATIONAL RELIABILITY OF AGRICULTURAL ELECTRICAL EQUIPMENT

**Abdullayev Bexzod Burxonjon o'g'li**

PhD student of Fergana Polytechnic Institute

E-mail: [behzodabdullayev19@gmail.com](mailto:behzodabdullayev19@gmail.com)

### ABSTRACT

This article reviews the current literature on the various factors that cause electrical wiring failure, such as temperature, humidity, and vibration, and best practices and techniques for improving electrical wiring reliability.

**Keywords:** Electricity, temperature, reliability, insulation.

Agriculture is an important sector of the world economy, contributing to food security, job creation and economic growth. In recent years, the use of electric drives, which replace traditional mechanical and hydraulic systems, has become increasingly widespread in agriculture. Electric drives have a number of advantages over traditional systems, such as increased energy efficiency, lower maintenance costs, and increased efficiency. However, their operational reliability remains a challenge, especially in harsh agricultural environments.

For a long time, it is known that the main and decisive factor affecting the reliability of insulation of electric machines is thermal wear. Therefore, methods for calculating the rate of thermal wear of insulation for the analysis of different operating modes are of particular importance. A model is proposed that connects temperature and insulation service life:

$$T_r = T_{r0} * e^{-\beta\theta} \quad (1)$$

The dispersion in the values of the  $\beta$  coefficient obtained during the processing of the experimental results did not have a well-founded explanation. For the convenience of using the expression (1), a rule was proposed, according to which overheating of the insulation by 8 °C halves the service life and leads to the following expression:

$$T_r = T_{r0} * 2^{-\frac{\theta}{\Delta\theta}} \quad (2)$$

Expressions (1) and (2) describe the process of thermal wear of insulation in the same way, therefore, based on their equality, the following model is obtained:

$$T_r = T_{r0} * e^{-\ln 2 \frac{\theta}{\Delta\theta}} \quad (3)$$

Nevertheless, the model described by the expression (3) expanded the possibility of further research and served as the beginning of the formulation of new rules for levels.

To assess reliability and determine an indicator capable of evaluating operating conditions, it seems to us that the Montzinger model is the most appropriate, in which the magnitude of the temperature rise is taken as an indicator of insulation wear under certain operating conditions and is determined from the following expression:

$$\Delta\theta = \frac{-\ln 2 * \theta}{\ln T_r - \ln T_{r0}} \quad (4)$$

It can be seen from the expression (4) that the value of insulation wear index  $\Delta\theta$  is directly proportional to the increase in the temperature of the coil and the failure of the electric motor, and is inversely proportional to the difference between the logarithms of the initial resource obtained by observing the dynamics. Table 1 shows the dependence of the working time of the electric motor on  $\Delta\theta$ .

Table 1.

Average time between failures of electric motors by test mode.

Test mode for electric motors with heat resistance class "E" insulation.	average working time	$\Delta\theta, ^\circ\text{C}$
1. Thermal wear at artificial load mode at $t = 160\text{ }^\circ\text{C}$	1432	10.11
2. Wear at temperature $t = 160\text{ }^\circ\text{C}$ and vibration acceleration with $A = 1.5\text{ g}$	593	9.37
3. wear at temperature $t = 160\text{ }^\circ\text{C}$ in idle mode and reverse mode at $A = 0.5\text{ g}$	330	8.92

In Table 2, different classes of heat resistance determined during the production process are defined for insulation

Table 2.

Temperature design limits

Issiqlikka qarshilik sinfi.	A	E	B	F
Issiqlik qarshilik sinflariga mos keladigan harorat, $\Delta\theta\text{ }^\circ\text{C}$	105	120	130	155

To determine a single indicator that reflects the entire set of operating conditions, we propose the well-known Montzinger expression, in which the value of  $\Delta\theta$  depends on the complete set of operating conditions.

$$T_r = T_{r0} * e^{-\ln 2 \frac{\theta}{\Delta\theta_{st} * K}} \quad (2.6)$$

Eliminating all dominant factors leads to an eightfold increase in resources. Correctly selected and well-tuned protection is required to eliminate faults related to overload and open-phase modes.

**Ways to increase operational reliability.** The most effective solution to increase operational reliability is related to the limitation of the maximum possible temperature of the insulation of the windings of electric motors, which reduces the level of destruction from the effects of aggressive environments in agricultural production and, in case of emergency overload, inevitable overheating elimination of departure.

### CONCLUSIONS

In order to evaluate the operational reliability of electric motors working in real technological processes of agricultural production, an integral index of working conditions (K) is proposed and the range of its change from 0.6 to 1.2 is determined. For the exponential law of the distribution of random variables, the method of separation of influencing factors, Weibull - Gnedenko and a model that allows forecasting of the resource in the elimination of failures and individual causes that take into account the influence of individual operational factors are proposed.

### REFERENCES:

1. Jaloliddinova Nozima Doniyorjon Kyzi, Sultanov Rozmatjon Anvarjon O'Gli Renewable sources of energy: advantages and disadvantages // Dostizheniya nauki i obrazovaniya. 2019. No. 8-3 (49). URL: <https://cyberleninka.ru/article/n/renewable-sources-of-energy-advantages-and-disadvantages> (data obrashcheniya: 01.12.2023).
2. Sultanov Ruzimatjon Anvarjon Ugli, Kodirov Husankhan Munavvarkhan Ugli, Mirzaliev Boburbek Bakhtiyorovich Vybor mechanical engine electric current, ispolzuemyx v system elektroprivoda // Problemy Nauki. 2019. No. 11-2 (144). URL: <https://cyberleninka.ru/article/n/vybor-mehanicheskikh-dvigatelye-elektricheskogo-toka-ispolzuemyh-v-sisteme-elektroprivoda> (data obrashcheniya: 01.12.2023).
3. Sultanov Ruzimatjon Anvarjon Ugli Recommendations for production of electric energy and compensation of wasted energy with auxiliary system cooling of electric motors // Vestnik nauki i obrazovaniya. 2019. No. 19-3 (73). URL: <https://cyberleninka.ru/article/n/rekomendatsii-po-vyrabotke-elektroenergii-i-kompensatsii-poteryannoy-energii-s-pomoschyu-sistemy-ohlazhdeniya-elektrodvigatelye> (data obrashcheniya: 01.12.2023).
4. Usmanov Shukurillo Yulbarovich, Sultunov Ruzimatjohn Anvarjohn O'Gli, Kuchkarova Dilnoza Toptievna Research potential of energy saving pump unit and hydraulic network // Problemy Nauki. 2019. No. 12-1 (145). URL: <https://cyberleninka.ru/article/n/research-potential-of-energy-saving-pump-unit-and-hydraulic-network> (data obrashcheniya: 01.12.2023).

5. Usmanov SY Analysis of Working Modes of Well Pumping Equipment Electr //Central Asian Journal of Theoretical and Applied Science. - 2022. - T. 3. – no. 11. – S. 119-125.
6. Yulbarsovich US, Nurillaevich MN FREQUENCY CONTROL OF POWER EQUIPMENT DURING SECONDARY STEAM GENERATION IN THE PRODUCTION UNIT // PRINCIPAL ISSUES OF SCIENTIFIC RESEARCH AND MODERN EDUCATION. - 2022. - T. 1. – no. 6.
7. Yulbarsovich US et al. MEASUREMENT AND CONTROL OF THE LOAD OF ENERGY DEVICES //Galaxy International Interdisciplinary Research Journal. - 2023. - T. 11. – no. 4. – S. 663-666.
8. Yu US, Sultanov RA NONLINEAR FEEDBACK CONTROL IN INTELLIGENT AC MOTOR CONTROL //Advancing in research, practice and education. - 2022. - T. 9. - S. 188.
9. Usmanov Sh. Yu., Sultanov R. A. U., Kuchkarova D. T. SINTEZ ALGORITMOV INTELLECTUALNOY SISTEMY UPRAVLENIYA MNOGOSVYazNYMI ELEKTROPRIVODAMI //Universum: tekhnicheskie nauki. – 2022. – no. 1-3 (94). - S. 50-53.
10. Usmanov Sh. Yu., Kuchkarova D. T., Sultanov R. A. Automatic system control of machines and aggregates of shelkomotania na osnobe energosberegayushchego elektroprivoda //Universum: tekhnicheskie nauki. – 2021. – no. 12-6 (93). - S. 37-41.
11. Sultanov RA, Shermatov BA IMPROVING PRODUCT QUALITY BY REDUCING THE ENERGY CONSUMPTION OF ELECTRIC DRIVES IN THE SILK INDUSTRY // Economics and society. – 2021. – no. 11-1 (90). - S. 538-544.